



Adopted

Updated October 18, 2024

Entiat School District Action Plan: Lead in Drinking Water

School Information

School Name(s): Paul Rumburg Elementary; Entiat Middle and High School

School District: Entiat School District #127

County: Chelan County

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
Paul Rumburg Elementary	9/13/2024	10/16/2024	<input checked="" type="checkbox"/> DOH (for sampling and testing) <input type="checkbox"/> Other: [Click here to enter sampling and testing provider name(s)]
Entiat Middle & High School	9/13/2024	10/16/2024	<input checked="" type="checkbox"/> DOH (for sampling and testing) <input type="checkbox"/> Other: [Click here to enter sampling and testing provider name(s)]
[Click here to enter school name]	[Click here to enter date]	[Click here to enter date]	<input type="checkbox"/> DOH (for sampling and testing) <input type="checkbox"/> Other: [Click here to enter sampling and testing provider name(s)]

Testing Requirements

[RCW 28A.210.410](#) and [RCW 43.70.830](#) require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an [accredited lab](#).

Action Plan Requirements

If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If your school has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per [RCW 28A.210.410](#), a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with [DOH's technical guidance](#).
- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI [Lead in Water Remediation Grant](#) is a potential source of funding.
- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.
- For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.
- The action plan must include:
 - 1) **Mitigation measures** implemented since receiving elevated lead test results.
 - 2) A schedule of **remediation activities** that adhere to the [technical guidance](#). The schedule may be based on the availability of state or federal funding for remediation activities.
 - 3) A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb.

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as “hand wash only,” to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the [technical guidance](#).

The Entiat School District **Error! Reference source not found.Error! Reference source not found.Error! Reference source not found.Error! Reference source not found**.has identified 12 drinking water outlets with elevated lead levels requiring mitigation. For all fixtures, the immediate steps we took included shutting off the water supply to each of the fixtures involved. We also placed signs saying “No Drinking.”

Mitigation measures have been implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	9/13/2024	389678	Entiat S.D Paul Rumburg Elementary	Sink - Multi-Compartment; 151 Work Rm; 1 of 1; Tap; center	35	Shut off water supply to fixture; place sign saying “No Drinking; Handwashing Only”; <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	10/17/2024
2)	9/13/2024	389676	Entiat S.D. Paul Rumburg Elementary	Sink; Health Rm 152C 1 of 1; Tap; center	8	Shut off water supply to fixture; place sign saying “No Drinking; Handwashing Only”; <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	10/17/2024
3)	9/13/2024	389679	Entiat S.D. Entiat Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 4 of 5	59	Shut off water supply to fixture; place sign saying “No Drinking; Handwashing Only”; <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	[Click here to enter date]10/17/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

4)	9/13/2024	389677	Entiat S.D. Entiat Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 3 of 5	29	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	[Click here to enter date] 10/17/2024
5)	9/13/2024	389693	Entiat S.D. Entiat Middle & High School	Sink; Rm 120; Tap; Center	29	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; temporary <input checked="" type="checkbox"/> permanent	10/17/2024
6)	9/13/2024	389673	Entiat S.D - Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 1 of 5	28	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; temporary <input checked="" type="checkbox"/> permanent	10/17/2024
7)	9/13/2024	389681	Entiat S.D - Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 5 of 5	26	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; temporary <input checked="" type="checkbox"/> permanent	10/17/2024
8)	9/13/2024	389688	Entiat S.D - Middle & High School	Sink; Rm 103; Tap; Center	26	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; temporary <input checked="" type="checkbox"/> permanent	10/17/2024
9)	9/13/2024	389685	Entiat S.D - Middle & High School	Sink; Rm 113; Tap; Center	24	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; temporary <input checked="" type="checkbox"/> permanent	10/17/2024
10)	9/13/2024	389683	Entiat S.D - Middle & High School	Sink; Rm 111; Tap; Center	22	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; temporary <input checked="" type="checkbox"/> permanent	10/17/2024
11)	9/13/2024	389663	Entiat S.D - Middle & High School	Sink; Rm 108; Tap; Center	21	Shut off water supply to fixture; place sign saying "No Drinking;	10/17/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

						Handwashing Only"; <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	
12)	9/13/2024	389692	Entiat S.D - Middle & High School	Sink; Rm 105; Tap; Center	15	Shut off water supply to fixture; place sign saying "No Drinking; Handwashing Only"; <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	10/17/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

3)	[Click here to enter date] 9/13/2024	389679	Entiat S.D. Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 4 of 5	59	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/2024
4)	[Click here to enter date] 9/13/2024	389677	Entiat S.D. Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 3 of 5	29	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/2024
5)	9/13/2024	389693	Entiat S.D - Middle & High School	Sink; Rm 120; Tap; Center	29	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24
6)	9/13/2024	389673	Entiat S.D - Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 1 of 5	28	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24
7)	9/13/2024	389681	Entiat S.D - Middle & High School	Sink - Multi-Compartment; Rm 109; Tap; Center; 5 of 5	26	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24
8)	9/13/2024	389688	Entiat S.D - Middle & High School	Sink; Rm 103; Tap; Center	26	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24
9)	9/13/2024	389685	Entiat S.D - Middle & High School	Sink; Rm 113; Tap; Center	24	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24
10)	9/13/2024	389683	Entiat S.D - Middle & High School	Sink; Rm 111; Tap; Center	22	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

11)	9/13/2024	389663	Entiat S.D - Middle & High School	Sink; Rm 108; Tap; Center	21	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24
12)	9/13/2024	389692	Entiat S.D - Middle & High School	Sink; Rm 105; Tap; Center	15	<ul style="list-style-type: none"> • Replace fixtures. • Retest • Possibly add filter 	12/31/24

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

Post-Remediation Testing

School Name	Completed Post-Remediation Testing	Planned Post-Remediation Testing
Paul Rumburg Elementary	<p>[Enter # of outlets here] outlets have been sampled and retested by:</p> <p><input type="checkbox"/> DOH</p> <p><input type="checkbox"/> a contractor</p> <p>Sampling date: [Click here to enter date]</p>	<p>[Enter # of outlets here] outlets will be sampled and retested by:</p> <p><input type="checkbox"/> DOH</p> <p><input type="checkbox"/> a contractor</p> <p><input type="checkbox"/> TBD</p> <p>Sampling is scheduled for: [Click here to enter date]</p>
Entiat S.D - Middle & High School	<p>[Enter # of outlets here] outlets have been sampled and retested by:</p> <p><input type="checkbox"/> DOH</p> <p><input type="checkbox"/> a contractor</p> <p>Sampling date: [Click here to enter date]</p>	<p>[Enter # of outlets here] outlets will be sampled and retested by:</p> <p><input type="checkbox"/> DOH</p> <p><input type="checkbox"/> a contractor</p> <p><input type="checkbox"/> TBD</p> <p>Sampling is scheduled for: [Click here to enter date]</p>

Communication Plan

The Entiat School District will communicate information about the plan for remedial action to reduce lead concentrations in drinking water through REMIND and on our School Website. In October of each year, this information will be communicated annually until post-remediation retesting does not detect an elevated lead level (above 5 ppb) at any drinking water outlet.

Contact Information

The following person(s) is the main point of contact for more information related to this action plan.

Name: Greg Whitmore

Role: Superintendent

Email: gwhitmore@entiatschools.org

Phone: 509-784-1800 #3

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]