

Lead in School Drinking Water Report

Paul Rumburg Elementary School



Date(s) collected: 2024-09-13

Date(s) analyzed: 2024-09-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389678	Paul Rumburg Elementary	Sink - Multi-Compartment	151 Work Rm	1 of 1	Tap	center	35
389676	Paul Rumburg Elementary	Sink	Health Rm 152 C	1 of 1	Tap	center	8
389934	Paul Rumburg Elementary	Sink	Rm 206	1 of 1	Water Bottle Filler	right	3

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389664	Paul Rumburg Elementary	Sink	Concessions	1 of 1	Tap	center	2
389924	Paul Rumburg Elementary	Sink	Rm 207	1 of 1	Tap	left	2
389926	Paul Rumburg Elementary	Sink	Rm 207	1 of 1	Water Bottle Filler	right	2
389928	Paul Rumburg Elementary	Sink	Rm 208	1 of 1	Tap	left	2
389930	Paul Rumburg Elementary	Sink	Rm 208	1 of 1	Water Bottle Filler	right	2
389932	Paul Rumburg Elementary	Sink	Rm 206	1 of 1	Tap	left	2
389672	Paul Rumburg Elementary	Fountain	Main Gym	1 of 2	Water Fountain	left	1
389901	Paul Rumburg Elementary	Sink	Rm 158	1 of 1	Tap	left	1
389903	Paul Rumburg Elementary	Sink	Rm 158	1 of 1	Water Bottle Filler	right	1
389910	Paul Rumburg Elementary	Sink	Rm 218	1 of 1	Tap	left	1
389912	Paul Rumburg Elementary	Sink	Rm 218	1 of 1	Water Bottle Filler	right	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389923	Paul Rumburg Elementary	Fountain/Tap Combo	Rm 013	1 of 1	Tap	left	1
389936	Paul Rumburg Elementary	Sink	Rm 156	1 of 1	Tap	left	1
389660	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Fountain	right	<1
389662	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Bottle Filler	right	<1
389666	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Small Gym	1 of 1	Water Fountain	left	<1
389668	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Small Gym	1 of 1	Water Fountain	right	<1
389670	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Small Gym	1 of 1	Water Bottle Filler	right	<1
389674	Paul Rumburg Elementary	Water Bottle Filling Station	Main Gym	2 of 2	Water Bottle Filler	center	<1
389900	Paul Rumburg Elementary	Pot Filler	Kitchen	1 of 3	Sprayer	center	<1
389902	Paul Rumburg Elementary	Sink - Multi-Compartment	Kitchen	2 of 3	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389904	Paul Rumburg Elementary	Sink	Kitchen	3 of 3 (dripping faucet)	Tap	center	<1
389905	Paul Rumburg Elementary	Sink	Rm 157	1 of 1	Tap	left	<1
389906	Paul Rumburg Elementary	Sink	Rm 219	1 of 1	Tap	left	<1
389907	Paul Rumburg Elementary	Sink	Rm 157	1 of 1	Water Bottle Filler	right	<1
389908	Paul Rumburg Elementary	Sink	Rm 219	1 of 1	Water Bottle Filler	right	<1
389909	Paul Rumburg Elementary	Sink	Rm 153	1 of 1	Tap	left	<1
389911	Paul Rumburg Elementary	Sink	Rm 153	1 of 1	Water Bottle Filler	right	<1
389913	Paul Rumburg Elementary	Fountain/Tap Combo	Rm 005	1 of 1	Tap	left	<1
389914	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Upper Floor Elementary Hallway	1 of 1	Water Fountain	left	<1
389915	Paul Rumburg Elementary	Fountain/Tap Combo	Rm 005	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389916	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Upper Floor Elementary Hallway	1 of 1	Water Fountain	right	<1
389917	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Lower Floor Elementary Hallway	1 of 1	Water Fountain	left	<1
389918	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Upper Floor Elementary Hallway	1 of 1	Water Bottle Filler	right	<1
389919	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Lower Floor Elementary Hallway	1 of 1	Water Fountain	right	<1
389920	Paul Rumburg Elementary	Sink	Rm 203	1 of 1	Tap	left	<1
389921	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Lower Floor Elementary Hallway	1 of 1	Water Bottle Filler	right	<1
389922	Paul Rumburg Elementary	Sink	Rm 203	1 of 1	Water Bottle Filler	right	<1
389925	Paul Rumburg Elementary	Fountain/Tap Combo	Rm 013	1 of 1	Water Fountain	right	<1
389927	Paul Rumburg Elementary	Sink - Multi-Compartment	Rm 012	1 of 1	Tap	center	<1
389929	Paul Rumburg Elementary	Sink	Rm 010	1 of 1	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389931	Paul Rumburg Elementary	Sink	Rm 010	1 of 1	Water Bottle Filler	right	<1
389933	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Elementary Bathroom	1 of 1	Water Fountain	left	<1
389935	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Elementary Bathroom	1 of 1	Water Fountain	right	<1
389937	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Elementary Bathroom	1 of 1	Water Bottle Filler	right	<1
389938	Paul Rumburg Elementary	Sink	Rm 156	1 of 1	Water Bottle Filler	right	<1
389939	Paul Rumburg Elementary	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Fountain	left	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: leadfreekids@doh.wa.gov